

November 21, 2023

VI 2347629:1-4 **Coliform Bacteria Analysis**

Customer ID : 4020266

**Water System Solutions**

South Fork Estates MWC

Attn: Thomas Ridenour

403 Scranton Ave.

Porterville, CA 93257

System Number : CA5403113

Project Name : Monthly Bacteriological

**Analytical Results**

ID	Sample Description	Total	Fecal	E. Coli	Units	Method	Prep	Footnote
1	Well 02	<b>Absent</b>	---	<b>Absent</b>	A/P/100ml	SM 9223B	Colilert-P/A 18	
2	Storage Tank	<b>Absent</b>	---	<b>Absent</b>	A/P/100ml	SM 9223B	Colilert-P/A 18	
3	Quail Run	<b>Absent</b>	---	<b>Absent</b>	A/P/100ml	SM 9223B	Colilert-P/A 18	
4	Black Oaks	<b>Absent</b>	---	<b>Absent</b>	A/P/100ml	SM 9223B	Colilert-P/A 18	

N/R Not Required

MPN Most Probable Number

A/P Absence/Presence

**The samples listed above were Acceptable for both Total and Fecal Coliform**

**Sample Handling Information**

ID	Sample Number	System Number	Sample Type/Reason	Sampler	Employed By	Sampled
1	VI 2347629-001	CA5403113_002_002	Source-Other	Thomas R.	Not Available	2023-11-10 10:30
2	VI 2347629-002	5403113	System-Other	Thomas R.	Not Available	2023-11-10 10:40
3	VI 2347629-003	5403113	System-Other	Thomas R.	Not Available	2023-11-10 10:25
4	VI 2347629-004	5403113	System-Routine	Thomas R.	Not Available	2023-11-10 10:50

**Field Analysis/QA Information**

ID	Sample Description	Cl Total/Free mg/l	Temp	Analysis Started	Analysis Completed	Contact	Contacted
1	Well 02	---/---	---	2023-11-10 15:01 ios	2023-11-11 10:25 mbc	N/R	
2	Storage Tank	---/---	---	2023-11-10 15:01 ios	2023-11-11 10:25 mbc	N/R	
3	Quail Run	---/---	---	2023-11-10 15:02 ios	2023-11-11 10:25 mbc	N/R	
4	Black Oaks	---/---	---	2023-11-10 15:02 ios	2023-11-11 10:25 mbc	N/R	

Analyses were performed at the FGL Visalia Laboratory using Standard Methods 20th edition. If you have any questions regarding your results, please call. The FGL Visalia Laboratory is certified by California ELAP #2810 and accredited to ISO/IEC 17025:2017 by PJLA certificate #75605, Testing.

Prepared By: SMH

cc:SDHS-CDPH FRESNO-B

Reviewed and  
Approved By

**Raquel R. Harvey**



Digitally signed by Raquel R. Harvey  
Title: Tech Director Microbiology  
Date: 2023-11-21



<b>Client:</b> WSS- South Fork Estates MWC Address: Water System Solutions South Fork Estates MWC Attn: Thomas Ridenour 403 Scranton Ave. Porterville, CA 93257  Phone: (559)359-7172 Fax: Contact Person: Thomas Ridenour  <b>Project Name:</b> Monthly Bacteriological <b>Purchase Order Number:</b> <b>Quote Number:</b>		42527:11/06/2023  TEST DESCRIPTION - See Reverse side for Container, Preservative and Sampling information	
<b>Method of Sampling:</b> Composite(C) Grab(G) Type of Sample Potable(P) Non-Potable(NP) Ag Water(AgW) Bacti Type: Other(O) System(SYS) Source(SR) Waste(W) Bacti Reason: Routine(ROUT) Repeat(RPT) Replace(RPL) Other(O) Special(SPL) Coliform-Collifer-P/A 120ml(PBa)-Na2S2O3			
Sampling Fee: _____ Pickup Fee: _____ Time: _____ Compositor Setup Date: _____ Time: _____ Lab Number: VI 2347629 4-20266			
Sampler(s) <i>Thomas Ridenour</i>			
Sampling Fee: _____ Pickup Fee: _____ Time: _____ Compositor Setup Date: _____ Time: _____ Lab Number: VI 2347629 4-20266			
Samp Num 1 2 3 4	Location Description Well 02 Storage Tank Quail Run Black Oaks	Date Sampled 11/10/23 1 1 1	Time Sampled 1030 1040 1025 1050
Relinquished Received By: <i>[Signature]</i>		Date: 11/10/23 1354 Time:	Relinquished Received By: <i>[Signature]</i>
Relinquished Received By: <i>[Signature]</i>		Date: 11-10-2023 1354 Time:	Relinquished Received By: <i>[Signature]</i>

**Corporate Offices & Laboratory** IP # TH407  
 853 Corporation Street  
 Santa Paula, CA 93060  
 Phone: (805) 392-2000  
 Env Fax: (805) 525-4172 / Ag Fax: (805) 392-2063

**Office & Laboratory**  
 2500 Stagecoach Road  
 Stockton, CA 95215  
 Phone: (209) 942-0182  
 Fax: (209) 942-0423

**Office & Laboratory**  
 563 E. Limbo  
 Chico, CA 95926  
 Phone: (530) 343-5818  
 Fax: (530) 343-3807

**Office & Laboratory**  
 3442 Empresa Drive, Suite D  
 San Luis Obispo, CA 93401  
 Phone: (805) 783-2940  
 Fax: (805) 783-2912

**Office & Laboratory**  
 9415 W. Goshen Avenue  
 Visalia, CA 93291  
 Phone: (559) 734-9473  
 Fax: (559) 734-8435